

Certificate of constancy of performance



according to Regulation (EU) No. 305/2011

Certificate No.: 1008-CPR-MC 69266178 0001

Report No.: HU22ERYV 002

Applicant: **ALUSTRUKT-PLUS KFT.**
4080 Hajdúnánás, Liget út 8.
Hungary

Manufacturer: **ALUSTRUKT-PLUS KFT.**
4080 Hajdúnánás, Liget út 8.
Hungary

Manufacturing plant: **ALUSTRUKT-PLUS KFT.**
4080 Hajdúnánás, Pázsit út 37.
Hungary

Product: **Aluminium door-/frame construction type**
CS 77-FP (60) with glazing

Identification: **Aluminium door-/frame construction type**
CS 77-FP (60) with glazing

FPC Report No.: HU22MQEK 002

System of assessment and verification: 1

Tested according to: EN 16034:2014

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2022-06-24 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:
Budapest, 2022-06-24


Kristof Kertesz

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Essential characteristics	Performance	Harmonised technical specification
Fire resistance Classification Test Methods: EN 13501-2:2007+A1:2009 EN 1634-1:2014	E 60 EI ₁ 45 EI ₂ 60 EW 60	EN 16034:2014
Opening closing cycles EN 14600:2005	C0	



Certification Body

Date of issue:

Budapest, 2022-06-24

.....
 Kristof Kertesz